

**Consumer Confidence Report 2019
Water Quality
City of Havre de Grace**

The City of Havre de Grace is pleased to present the 21st Annual Consumer Confidence Report on Water Quality.

This report shows the quality of the water as pumped to your home from *Jan. 1 to Dec. 31, 2019*.

Explains the likely sources of contaminants,

Offers warnings for people in special risk groups; and,

Recommends measures all residents can take to help preserve the quality of water.

A brief summary of the results of our testing:

Our water is tested by two different laboratories. The testing results indicate that the City's drinking water meets or exceeds the standards required by *MDE/EPA* - the Maryland Department of the Environment and the Environmental Protection Agency.

Unregulated Contaminate Monitoring Rule (UCMR4)

The 1996 Amendments to the Safe Drinking Water Act (SDWA) **require that once every five years**, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminate Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. This national survey is one of the primary sources of information on occurrence and levels of exposure that the Agency uses to develop regulatory decisions for contaminants in the public drinking water supply.

Contaminate	Level Detected	Unit of Measure
HAA5	17.24-45.9	ppb
HAA6Br	3.24-9.844	ppb
HAA9	23.908-51.798	ppb
Total Organic Carbon	1450-2380	ppb
BROMIDE	23.4-36.3	ppb
MANGANESE	0.71-1.96	ppb

For additional information: <https://www.epa.gov/sites/production/files/2017-03/documents/ucmr4-fact-sheet-general.pdf>

**WATER QUALITY
CONSUMER CONFIDENCE REPORT
HAVE QUESTIONS? We're here for you.**
City Water Plant: 410-939-1070 (24 hrs a day)
Department of Public Works: 410-939-1800
Environmental Protection Agency: 800-426-4791



City of Havre de Grace
711 Pennington Avenue
Havre de Grace, MD 21078

PUBLIC NOTICE for JAN. 2019 to DEC. 2019

**Monitoring and Reporting Violation of the
Safe Drinking Water Act**

City of Havre de Grace

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During Jan. 1, 2019 to Dec. 2019, we completed testing for Nitrate but did not report it to the (MDE) Maryland Department of the Environment in a timely manner.

Water Treatment Plant Improvements

To keep water quality, technology and operations in top form and to meet the Safe Drinking Water Act (SDWA) requirements, equipment maintenance and replacement is an ongoing process. The Water Plant is in the process of a complete update. The Control Room will be replaced, complete reconstruction of the Flocculation System, Settling Tanks, Water Filters and associated piping. Work started on the Plant February 2020 and is scheduled to be completed by August 2021. EMH Environmental, Inc. is the contractor.

Planned Upgrades for Distribution System

Scheduled for 2020. To address the needs of our aging infrastructure, the city has a number of projects identified this year. The city will have approximately 1,000 linear feet of existing 4" and 6" water line replaced with 8" water main. Approximately 2,000 linear feet of existing 12" terra cotta sewer main will be replaced throughout the city. In addition, a new water main will be constructed to loop the existing water system at Old Bay Lane, and an existing pump station and force main will be replaced. Also, the Water Distribution team will also replace old valves and fire hydrants throughout the city.

Preserve Water Quality - Recommendations

- ◆ Flush your water heater once a year.
- ◆ Clean the screens on your spigots.
- ◆ When water has not been used for several hours, run the cold water at least 30 seconds to insure you are receiving fresh water from the main instead of dormant water in your pipes.
- ◆ Make sure the water shut-off valve inside your home is operable in case you have a leak and need to shut-off the supply immediately.

Any changes in your water pressure, taste or color should be reported as soon as possible. Call the Water Plant at 410-939-1070. Staff on site 24/7.



Important to know: The EPA has determined that your water is safe.

The Susquehanna River is the source of your drinking water. The Environmental Protection Agency (EPA) recognizes that all drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some 22 known contaminants. Both Federal and State laws require the city to routinely monitor the levels of these possible contaminants in your drinking water.

The Source of this Water Assessment is available on MDE's website at:

[https://mde.maryland.gov/programs/Water/water supply/Source Water Assessment Program/Documents/Havre%20de%20Grace.pdf](https://mde.maryland.gov/programs/Water/water%20supply/Source%20Water%20Assessment%20Program/Documents/Havre%20de%20Grace.pdf)

Note: While not mandated by the Environmental Protection Agency or the Maryland Department of the Environment, the city's Department of Public Works tests both the Source Water and Finished Water for the presence of Polyfluoralkyl (PFAS) Substances. The results of these tests showed No Presence of substances. For more information, visit: www.havredegracemd.com

Precautions for Special Risk Groups

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Immunocompromised persons such as those undergoing chemotherapy, those with HIV/AIDS or other immune system disorders, those having undergone organ transplants, some elderly and infants, can be particularly vulnerable to contaminants in drinking water. These special risk groups should seek advice from their health care providers.

DEFINITIONS

Action Level – The concentration of a contaminant which can trigger improved treatment techniques or other requirements which a water system must follow.

Compliance Level-The value used to determine compliance with EPA or State regulations.

Intestinal Parasites: Microorganisms like Cryptosporidium and Giardia lamblia can cause gastrointestinal illness such as cramps, diarrhea, vomiting.

Maximum Contaminant Level (MCL): *Maximum Allowed* is the highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for an extra margin of safety.

Ninetieth Percentile (90th %) for lead & copper testing only. Ninety percent of the homes where the tap water was tested, are at or below this value. EPA only requires the voluntary testing of homes built between 1983 and 1986, where lead solder has been used in the plumbing.

Parts per million (ppm), per billion (ppb), per trillion (ppt)
Measurement units for the level of contaminants in water.
One ppm corresponds to a single penny in \$10,000;
One ppb corresponds to one penny in \$10,000,000 and
One ppt corresponds to one penny in \$10,000,000,000.
LRAA = highest locational running annual average

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Total Coliform- Bacteria that are naturally present in the environment. They are used to indicate the presence of other potentially-harmful bacteria. CL is < 5 % positive each month.

Treatment Technique (TT) – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Turbidity - The cloudy appearance of water caused by the presence of suspended matter. Turbidity has no health effects. However, it can interfere with disinfection and provide a medium for microbial growth. **NTU** (Nephelometric Turbidity Units) is a unit of measure for the turbidity of water. A turbidity level of 5.0 NTU is just noticeable to the average person.

Unregulated Contaminants- Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCL	MCLG	Likely source of contamination
RADIOACTIVE CONTAMINANTS						
Beta/photon emitters	N	ND-2013 due again 2022	mrem/yr	4	0	Decay of natural and man-made deposits
Alpha emitters	N	ND-2013 due again 2022	pCi/L	15	0	Erosion of natural deposits
Combined radium	N	ND-2004 due again 2022	pCi/L	5	0	Erosion of natural deposits
INORGANIC CONTAMINANTS						
Barium	N	.029	ppm	2.0	2.0	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper	N	0.08 Next test 2022	ppm	AL= 1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	N	0.71 mg/l	ppm	4.0	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Beryllium	N	<0.005	ppb	4	4	Discharge from metal refineries and coal-burning factories.
Mercury (inorganic)	N	<0.002	ppb	2.0	2.0	Erosion of natural deposits, discharge from refineries and factories, runoff from landfills, runoff from cropland
Nitrate (as Nitrogen)	N	2.15	ppm	10.0	10.0	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
DISINFECTION BY PRODUCTS						
Chlorine	N	0.6 - 3.78	ppm	4.0	4.0	Water additive used to control microbes
TTHM Total Trihalomethanes	N	16.3 - 109 (LRAA 51 ppb)	ppb	80.0 LRAA	NA	By-product of drinking water chlorinating CL=Rolling yearly avg. by quarter
HAA5 Haloacetic Acids	N	2.83 - 48.1 (LRAA 41 ppb)	ppb	60.0 LLRA	NA	By-product of drinking water chlorinating CL=Rolling yearly avg. by quarter
MICROBIOLOGICAL CONTAMINANTS						
Cryptosporidium	N	Not detected	TT		0	Human and animal fecal wastes
Giardia Lamblia	N	Not detected	TT		0	Human and animal fecal wastes
Total Coliforms	N	0.00		<5%	0	Naturally present in the environment
Total Organic Carbon	N	1.03 - 3.73 range	TT	TT	NA	Naturally present in the environment CL based on % removal
Turbidity	N	.013 - .230 range	NTU	0.3	NA	Soil run-off
NON-REGULATED CONTAMINANTS						
Sodium	N	5.58 - 46.4	ppm	NA	NA	Naturally present in the environment
Chloride	N	26 - 56	ppm	NA	NA	Naturally present in the environment
Alkalinity	N	30 - 74	ppm	NA	NA	Naturally present in the environment
Hardness	N	40 - 116	ppm	NA	NA	Naturally present in the environment
pH	N	6.71 - 8.04	STD	NA	NA	Soil run-off