

Consumer Confidence Report 2021 Water Quality City of Havre de Grace

The City of Havre de Grace is pleased to present the 21st Annual Consumer Confidence Report on Water Quality.

This report shows the quality of the water as distributed directly to your home from *Jan. 1 to Dec. 31, 2021*.

Explains the likely sources of contaminants,
Offers warnings for people in special risk groups; and,
Recommends measures all residents can take to help preserve the quality of water.

A brief summary of the results of our testing:
Our water is tested by two different laboratories. The testing results indicate that the City's drinking water meets or exceeds the standards required by *MDE/EPA* - the Maryland Department of the Environment and the Environmental Protection Agency.

Note: Currently, there are no federal regulations (i.e. Maximum Contaminant Levels (MCLs)) for PFAS in drinking water. However, the U.S. Environmental Protection Agency (EPA) has issued a Health Advisory Level (HAL) of 70 parts per trillion (ppt) for the sum of PFOA and PFOS concentrations in drinking water. While not an enforceable regulatory standard, when followed, the EPA HAL does provide drinking water customers, even the most sensitive populations, with a margin of protection from lifetime exposure to PFOA and PFOS in drinking water. Beginning in 2020, the Maryland Department of the Environment (MDE) initiated a PFAS monitoring program. The combined PFOA and PFOS concentration from samples taken from our water system was 5.94ppt. MDE anticipates that EPA will establish an MCL for PFOA and PFOS in the near future. This would entail additional monitoring. Additional information about PFAS can be found on the MDE website: mde.maryland.gov.

**WATER QUALITY
CONSUMER CONFIDENCE REPORT
HAVE QUESTIONS? We are here for you.**
City Water Plant: **410-939-1070 (24 hrs a day)**
Department of Public Works: **410-939-1800**
Environmental Protection Agency: **800-426-4791**



City of Havre de Grace
711 Pennington Avenue
Havre de Grace, MD 21078

Water Treatment Plant Improvements

To keep water quality, technology and operations in top form and to meet the Safe Drinking Water Act (SDWA) requirements, equipment maintenance and replacement continues to be an ongoing process. The Water Plant upgrade that started in 2020 will be completed by the end of June 2022. The Control Room will be moved to the Filter Room by the end of May and complete reconstruction of the Flocculation System, Settling Tanks, Water Filters and associated piping have already been completed. The Water Plant has also installed a new SCADA (Supervisory Control and Data Acquisition) is also being installed.

Planned Upgrades for Distribution System

Scheduled for 2022. To address the needs of our aging infrastructure, the city has a number of projects identified this year. The City is replacing the water line on Green Street and the water line on Wilson St. Both replacements are currently under construction and scheduled to be completed before then end of the Summer 2022. Over 1500 linear feet of water line is being replaced. Water Distribution will also replace old valves and fire hydrants throughout the city.

Preserve Water Quality - Recommendations

- ◆ Flush your water heater once a year.
- ◆ Clean the screens on your spigots.
- ◆ When water has not been used for several hours, run the cold water at least 30 seconds to insure you are receiving fresh water from the main, instead of dormant water in your pipes.
- ◆ Make sure the water shut-off valve inside your home is operable in case you have a leak and need to shut-off the supply immediately.

Any changes in your water pressure, taste or color should be reported as soon as possible. Call the Water Plant at **410-939-1070**. Staff on site 24/7.



Important to know: The EPA has determined that your water is safe.

The Susquehanna River is the source of your drinking water. The Environmental Protection Agency (EPA) recognizes that all drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some 22 known contaminants. Both Federal and State laws require the city to routinely monitor the levels of these possible contaminants in your drinking water.

The Source of this Water Assessment is available on MDE's website at:

https://mde.maryland.gov/programs/water/water_supply/ConsumerConfidenceReports/Documents/CCR2021/Harford%20County/0120012-City-of-Havre-de-Grace.pdf

Precautions for Special Risk Groups

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Immunocompromised persons such as those undergoing chemotherapy, those with HIV/AIDS or other immune system disorders, those having undergone organ transplants, some elderly and infants, can be particularly vulnerable to contaminants in drinking water. These special risk groups should seek advice from their healthcare providers.

DEFINITIONS

Action Level – The concentration of a contaminant which can trigger improved treatment techniques or other requirements which a water system must follow.

Compliance Level-The value used to determine compliance with EPA or State regulations.

Intestinal Parasites: Microorganisms like Cryptosporidium and Giardia lamblia can cause gastrointestinal illness such as cramps, diarrhea, vomiting.

Maximum Contaminant Level (MCL): *Maximum Allowed* is the highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for an extra margin of safety.

Ninetieth Percentile (90th %) for lead & copper testing only. Ninety percent of the homes where the tap water was tested, are at or below this value. EPA only requires the voluntary testing of homes built between 1983 and 1986, where lead solder has been used in the plumbing.

Parts per million (ppm), per billion (ppb), per trillion (ppt)
Measurement units for the level of contaminants in water.

One ppm corresponds to a single penny in \$10,000;

One ppb corresponds to one penny in \$10,000,000 and

One ppt corresponds to one penny in \$10,000,000,000.

LRAA = highest locational running annual average

PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Turbidity - The cloudy appearance of water caused by the presence of suspended matter. Turbidity has no health effects. However, it can interfere with disinfection and provide a medium for microbial growth. **NTU** (Nephelometric Turbidity Units) is a unit of measure for the turbidity of water. A turbidity level of 5.0 NTU is just noticeable to the average person.

Unregulated Contaminants- Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCL	MCLG	Likely source of contamination
RADIOACTIVE CONTAMINANTS						
Beta/photon emitters	N	ND-2013 due again 2022	mrem/yr	4	0	Decay of natural and man-made deposits
Alpha emitters	N	ND-2013 due again 2022	pCi/L	15	0	Erosion of natural deposits
Combined radium	N	ND-2004 due again 2022	pCi/L	5	0	Erosion of natural deposits
INORGANIC CONTAMINANTS						
Copper	N	0.08 Next test 2022	ppm	AL= 1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Barium	N	0.027 mg/l	ppm	2.0	2.0	Erosion of natural deposits
Nitrate (as Nitrogen)	N	1.74 mg/l	ppm	10.0	10.0	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
DISINFECTION BY PRODUCTS						
Chlorine	N	1.3-1.4	ppm	4.0	4.0	Water additive used to control microbes
TTHM Total Trihalomethanes	N	14.5-113 (LRAA 62 ppb)	ppb	80.0 LRAA	NA	By-product of drinking water chlorinating CL=Rolling yearly avg. by quarter
HAA5 Haloacetic Acids	N	11.41-49.9 (LRAA 32 ppb)	ppb	60.0 LLRA	NA	By-product of drinking water chlorinating CL=Rolling yearly avg. by quarter
MICROBIOLOGICAL CONTAMINANTS						
Total Organic Carbon	N	1.23-2.07 range	TT	TT	NA	Naturally present in the environment CL based on % removal
Turbidity	N	.026-0.281 range	NTU	0.3	NA	Soil run-off
NON-REGULATED CONTAMINANTS						
Sodium	N	5.61-41.8	ppm	NA	NA	Naturally present in the environment
Chloride	N	25-68	ppm	NA	NA	Naturally present in the environment
Alkalinity	N	30-78	ppm	NA	NA	Naturally present in the environment
Hardness	N	24-60	ppm	NA	NA	Naturally present in the environment
pH	N	6.54-8.62	STD	NA	NA	Soil run-off
PFAS	N	5.94	ppt	NA	NA	Cleaning products, paints, cookware, food packaging